# Example contractor (sample data)

PRESSURE TEST RECORD

SAMPLE
Example mark — not a company logo

**ACCEPTED**

Original · 2026-11-03 11:03 +00:00

## PROJECT

| PROJECT NUMBER | CLIENT | LOCATION |
|---|---|---|
| SAMPLE-2026-014 | Example client (not a real company) | Example fabrication yard |

## TEST OBJECT

| LINE / SYSTEM NO. | DRAWING / ISOMETRIC NO. | TEST MEDIUM |
|---|---|---|
| 6"-WC-101 | ISO-SAMPLE-014 rev A | Water |

## RECORDED VALUES

The values below were entered by the person who performed the test. This record does not calculate test pressure, hold period, or acceptance.

| DESIGN PRESSURE | TEST PRESSURE | HOLD PERIOD (RECORDED BY OPERATOR) |
|---|---|---|
| 16 bar(g) · Manually recorded | 24 bar(g) · Manually recorded | 30 min · Manually recorded |

**INITIAL READING**
24.0 bar(g) · Manually recorded · 2026-04-16 10:10 +00:00

**FINAL READING**
23.8 bar(g) · Manually recorded · 2026-04-16 10:42 +00:00

**AMBIENT**
12 °C · Manually recorded

**MEDIUM**
14 °C · Manually recorded

## RESULT

Sample hydrotest of a cooling-water spool. Example data only. Not a real test and not an acceptance by any code or client.

## GAUGES

### PG-SAMPLE-014 · Pressure gauge


0–40 bar(g) · S/N SN-SAMPLE-44821
Calibrated 2026-03-12 · Cal due 2027-03-12 · CAL-SAMPLE-2026-118 · Valid

# Example contractor (sample data)


PRESSURE TEST RECORD

## PHOTOS

Before · 2026-11-03 11:03 +00:00




After · 2026-11-03 11:03 +00:00




## SIGNATURES

The company on the record is the company name from settings, frozen when this revision was signed. It is not another person, and it is not the witness.

### TEST PERFORMED BY

Name: A. Example
Company on the record: Example contractor (sample data)
Signed: 2026-11-03 11:03 +00:00

### WITNESS

Name: B. Example
Witness company: Example inspection (sample)
Signed: 2026-11-03 11:03 +00:00

## REVISIONS

**Original · 2026-11-03 11:03 +00:00 · Signed by A. Example · Company on the record: Example contractor (sample data) · this PDF**

## INTEGRITY

SHA-256 of the canonical data for this signed revision. The hash does not cover the PDF file bytes.

```
a7e946c740e63e7595d1273fcf96f0503a1684688d6682673d74372223eb709d
```

Test ID 94250b05-d7d6-4809-8fc3-bf036b9bf501

Documentation and traceability. Pressure Test Log does not calculate pressure, hold period, or acceptance criteria.